

Why are P&ID's necessary?

Governmental Agencies: Occupational Safety and Health (Cal/FedOSHA) -Process Safety Management (PSM) Environmental Protection Agency (EPA)- Risk Management Plan (RMP) Unified Program Agency (UPA)- California Accidental Release Program (CalRP)

CALIFORNIA CUPA FORUM These Agencies regulate the use of hazardous chemicals, Regulated Substances (RS). Anhydrous Ammonia is identified as a RS. Ammonia's storage and usage, if above a threshold quantity (TQ), are regulated by the agencies listed on the left.

OSHA-Process Safety Management (PSM)

CUPA

OSHA 29 CFR 1910.119: A process involving chemical at or above the specified threshold quantities listed. For anhydrous ammonia, the TQ is 10,000 lbs& PSM applies. An Element of PSM is Process Safety Information (PSI). P&ID's are a part of this element and thus introducing P&ID's as a requirement.



25th California Unified Program Annual Training Conference March 20.02, 2022

OSHA-Process Safety Management (PSM)

Cal-OSHA Title 8 5189: California's version of 1910.119. P&ID's required only if a facility if above the threshold quantity. For both Cal-OSHA and fed OSHA, all TQ are the same for all RS. Ammonia's TQ is also 10,00dbs for PSM.

EPA- Risk Management Plan (RMP)

EPA Title 40 CFR part 68:

RMP rule implements section 112(r) of 1990 CAA for facilities that use TQ of extremely hazardous substances. For anhydrous ammonia, the TQ is also 10,000lbs require that an RMP be filed. Based on EPA Checklist RMP has 3 program levels. Level 3 has Process Safety information that is required.



EPA-Risk Management Plan (RMP)


Cal-EPA Title 19: Rule implement asthrough Cal-OES as Califomia Accidental Release Prevention Program (CalARP). The biggest difference between Fed RMP and CalARP is the TQ for any RS is typically much lower for our example, Anhydrous Ammonia is goolbs. Essentially, the vast majority of systems would need to develop a CalARP - RMP. Program level 3 facilities must compile PSI which includes P&ID.




25th California Unified Program Annual Training Conference March 20-23, 2023

CalARP Program 2 Safety Information

Maximum intended inventory designed in compliance the facility that makes the sofe upper and lower with recognized codes, safely information standards, and generally inaccurate the soft of the	Maximum intended inventory designed in compliance the facility that makes the with recognized codes, safety information	The owner/operator must compile and maintain this safety information:	The owner operator must ensure:	The owner/operator must update the safety information if:
codes and standards to design, engineering practices		Maximum intended inventory Safe upper and lower parameters Equipment Specifications codes and standards to design.	designed in compliance with recognized codes, standards, and generally accepted good	





CalARP Table 3 Risk Determinations

- CalARP Implementation Guidance, revised May 2020, Appendix F
- "The California Health and Safety Code Section 25534 requires the UPA to make a preliminary determination whether there is a significant likelihood that a facility's use of a Table 3 regulated substance poses an accident risk."



CalARP Table 3 Risk Determinations

SUPA

SUPA

- CalARP Implementation Guidance, revised May 2020, Appendix F, Suggestions for CalARP Program Facility Risk Ranking
- Option 1: If the facility has a chemical above the threshold quantity, in a process, an RMP is automatically required, no risk determinations are necessary. Every facility can be given the same RMP due date 12 months in advance. End of discussion.

th California Unified Program Annual Training Conference February 26-29, 2024

CalARP Table 3 Risk Determinations

- CalARP Implementation Guidance, revised May 2020, Appendix F, Suggestions for CalARP Program Facility Risk Ranking
- Option 2: If administrative reality or logic necessitates a graduated approach to requesting California-only RMPs, the following approach is one way to quantify the process of ranking each facility's potential risk to health and safety and the environment. This same process could be used by the UPA to justify Program 3 requirements. See Appendix F for methodology.


26th California Unified Program Annual Training Conference February26-29, 2024

CalARP Table 3 Risk Determinations


- CalARP Implementation Guidance, revised May 2020, Appendix F, Suggestions for CalARP Program Facility Risk Ranking
- Note of Caution: Whatever process is used, the UPA will need to
 establish and follow written policies and procedures and document each
 and every case where risk ranking is applied. This is to protect the UPA
 from possible accusations of being arbitrary and capricious, especially if
 competitors from the same industry are going to be impacted
 differently within the same jurisdiction or if environmental justice issues
 are raised.


CalARP Table 3 Risk Determinations

- CalARP Implementation Guidance, revised May 2020, Appendix F, Suggestions for CalARP Program Facility Risk Ranking
- Complete this process for every potential CalARP Program facility and rank the scores from highest to lowest.
- Develop criteria for establishing at what specific points RMPs (and/or Program 3) will be required.
- Commit the methodology to a written procedure and have your UPA management approve, adopt, or modify the policy


























.





































What is on a P&ID?

- PSM/ RMP Program 3/ CalARP P&ID:
- PSI requires P&ID as an element of the information pertaining to the equipment in the process.
 - Information

CALIFORNIA CUPA FORUM

- Manufacturer Name, Serial#, Model#, service specification, Pressure & Temperature Specification, size, etc.
- Pertaining to Equipment
 - Piping- piping connecting the individual instruments.

 - Instrumentation- Press. & Temp. control equipment, Flow equipment, Compressors, Condenser, Vessels, Pumps, Valves, Sensors, etc.


P&IDs Example-	D B I B I B I B I D <thd< th=""> <thd< th=""> <thd< th=""> <thd< th=""></thd<></thd<></thd<></thd<>		
Legend		Stati Image: Static Stati	
CALIFORNA TORUM			


Piping & Instrumentation Diagram (P&ID)


- Title Sheet schedule listing:
 - All diagrams in the drawing set.
 - Legend with piping/mechanical symbols & abbreviations
 - General notes -


- piping specifications
- ANSI/ASME B31.5 or IIAR-2 references
- pipe labeling, valve tagging, safety valve and other information relating to the refrigeration system










































TAG#	SIZE	LINE	STAT		DESCRIPTION	DWG	LOCATION	COMMENTS/NOTE:
HS01		ALL ARE		Canada	FRICK HIGH STACE SCREW COMPRESSOR INC MODEL - IRWEIL270	R-02/10	COMPRESSOR ROOM	S/N: XXXXX (2018)
FF# L97004					+25'F SST / +85'F SDT - 632.4 TONS @ 578.1 RHP			
					MOTOR: 625 HP (55)			
0501					FRICK OIL SEPARATOR: 35'0 X XX-0" OAL	R-02/10	HS01	N/B: XXXXX
FF# L97016					DESIGN PRESSURE / TEMPERATURE: XXX PSI @ +XXX*F/30/F			S/N: XXXXX (2018)
H901-01	8"	HTS	N.O.	AV	ANGLE SHUT-OFF VALVE	R-02/10	H901	
H501-02	8"	HTS	N.C.	CV	CHECK VALVE	R-02/10	H501	
H901-03	6"	HSD	N.O.	AV	ANGLE SHUT-OFF VALVE	R-02/10	H901	
HS01-04	6"	HSD	N.C.	CV	STOP/CHECK VALVE	R-02/10	HS01	
H901-05	5/47	HSD	N.C.	AV	ANGLE SHUT-OFF VALVE	R-02/10	H901	SERVICE VALVE
HS01-05	3/4"	RV		WV	THREE-WAY VALVE	R-02/10	HS01	
HS01-07	3/4*	RV		RV	RELIEF VALVE	R-02/10	HS01	SHANK #814 @ 300 PS
HS01-08	3/4*	RV		RV	REUEF VALVE	R-02/10	HS01	SHANK #814 @ 300 PS
HS01-09	3/4"	LIC	N.O.	GV	GLOBE SHUT-OFF VALVE	R-02/10	HS01	DANFOSS #ICF-208
HS01-10	3/4"	UC		MV	MOTORIZED VALVE	R-02/10	H501	DANFOSS #ICF-208
HS01-11	3/4"	UC	N.C.	sv	SOLENOID VALVE	R-02/10	HS01	DANFOSS #ICF-208
HS01-12								
HS01-13	34*	UC		ST	STRANER	R-02/10	HS01	DANFOSS MCF-208
H901-14	3.8.	UC	N.C.	AV	ANGLE SHUT-OFF VALVE	R-02/10	H901	SERVICE VALVE
H501-15	2/4"	LIC	N.O.	GV	GLOBE SHUT-OFF VALVE	R-02/10	HS01	DAMPOSS MCP-208
HS01-16	3/4"		N.C.	AV	ANGLE SHUT-OFF VALVE	R-02/10	H801	PUMPOUT
H501-17	1/2"	OD	N.C.	AV	ANGLE SHUT-OFF VALVE	R-02/10	H501	SERVICE VALVE
H901-18	2-1/2"	OD	N.O.	AV	ANGLE SHUT-OFF VALVE	R-02/10	HS01	
HS01-19	5/6"	OD	N.O.	AV	ANGLE SHUT-OFF VALVE	R-02/10	H501	TRANSDUCER VALVE
H901-20	1/2"	OD	N.C.	AV	ANGLE SHUT-OFF VALVE	R-02/10	H901	SERVICE VALVE
H501-21	516"	OD	N.C.	AV	ANGLE SHUT-OFF VALVE	R-02/10	H501	SERVICE VALVE
HS01-22	2-1/2"	OD	N.O.	AV	ANGLE SHUT-OFF VALVE	R-02/10	H801	
HS01-23	5/4"	OD	N.O.	AV	ANGLE SHUT-OFF VALVE	R-02/10	H501	












Process Hazard Analysis

The PHAshall be appropriate to the complexity of the process and shall **identify**, evaluate, and control the hazards involved in the process.

The owneror operator **shall work closely** with UPAs in deciding which PHA methodology is best suited to determine the hazards of the process being analyzed. Ow/Op shall use one or more of the following methodologies that are appropriate to determine and evaluate the hazards of the process being analyzed:

> (1) What-If* (2) Checklist* (3) What-If / Checklist* (4) Haraci and Operability Study(H4ZOB); (5) Fault Tree Analysis, or, (7) An appropriatequivalent methodology.










Process Hazard Analysis – brief overview


- At least onceevery five years from the date of initial submission or most recent update;
 No later than three years after a newly regulated substance is first listed;
 No later than the date on which a new regulated substance is first present in an
- already covered process above a threshold quantity; No later than the date on which a regulated substance is first present above a threshold .
- •
- quantity in a new process; Within six months of a change that requires a revised PHA or hazard review;
- Within sixmonths of a change that requires a revised OCA; and, Within sixmonths of a change that alters the Program level. :





Process Safety Rule	PROGRAM REQUIREMENT	CALARP	EPA	CALOSHA	OSHA
explicitly stated	Program Levels 1, 2, and 3	Yes	Yes	No	No
, ,	Management System	2735.6	68.15		
	Hazard Assessment/Offsite Consequence Analysis	2750.1-9	68.20 -42		
	Process Safety Information	2760.1	68.65	5189(d)	1910.119(d)
	Process Hazard Analysis	2760.2	68.67	5189(e)	1910.119(e)
	Operating Procedures	2760.3	68.69	5189(f)	1910.119(f)
	Training	2760.4	68.71	5189(g)	1910.119(g)
	Mechanical Integrity	2760.5	68.73	5189(j)	1910.119(j)
	Management of Change	2760.6	68.75	5189(l)	1910.119(l)
	Pre-Startup Safety Review	2760.7	68.77	5189(i)	1910.119(i)
	Compliance Audit	2760.8	68.79	IIPP	1910.119(o)
	Incident Investigation	2760.9	68.81	5189(m)	1910.119(m)
	Employee Participation	2760.10	68.83	5189(p)	1910.119(c)
	Hot Work Permits	2760.11	68.85	5180(k)	1010.110(k)
	Contractors	2760.12	68.87	5189(h)	1910.119(h)
	Emergency Planning & Response	2765.1 - 2	68.95	5189(n)	1910.119(n)
CALIFORNIA	Trade Secrets		7.0		1910.119(p)


Where do yo Process Safety Ru	PROGRAM REQUIREMENT	CALARP	EPA	CALOSHA	OSHA
mplied use	Program Levels 1, 2, and 3	Yes	Yes	No	No
	Management System	2735.6	68.15		
	Hazard Assessment/Offsite Consequence Analysis	2750.1-9	68.20 -42		
	Process Safety Information	2760.1	68.65	5189(d)	1910.119(d)
	Process Hazard Analysis	2760.2	68.67	5189(e)	1910.119(e)
	Operating Procedures	2760.3	68.69	5189(f)	1910.119(f)
	Training	2760.4	68.71	5189(g)	1910.119(g)
	Mechanical Integrity	2760.5	68.73	5189(j)	1910.119(j)
	Management of Change	2760.6	68.75	5189(l)	1910.119(l)
	Pre-Startup Safety Review	2760.7	68.77	5189(i)	1910.119(i)
	Compliance Audit	2760.8	68.79	IIPP	1910.119(o)
	Incident Investigation	2760.9	68.81	5189(m)	1910.119(m)
	Employee Participation	2760.10	68.83	5189(p)	1910.119(c)
	Hot Work Permits	2760.11	68.85	5180(k)	1010.110(k)
	Contractors	2760.12	68.87	5189(h)	1910.119(h)
	Emergency Planning & Response	2765.1 - 2	68.95	5189(n)	1010.110(n)
	Trade Secrets		7.0		1910.119(p)







Where would you see P&IDs? Process Modification (CCR 2745.11)



Process Modification

(a) Where reasonably possible, <u>notify the UPA in writing</u> of the owner or operator's intent to modify the stationary source at least five calendar days before implementing any modifications. As part of the notification process, the owner or operator <u>shall consite</u> with the UPA when <u>determining</u> whether the RMP should be reviewed and revised. Where prenotification is not reasonably possible, the owner or operator shall provide written notice to the UPA no later than 48 hours following the modification.

(2) Establish procedures to manage the proposed modification, which <u>shall be substantially similar</u> to the procedures specified in Sections 2760.6 and 2760.7 and notify the UPA that the procedures have been established.

There one reasonation of the stationary source shall revise the appropriate documents, as required pursuant to section (a), <u>expeditionsly</u>, <u>but not later than 60 days</u> from the date of the stationary source modification.



Process Modification


CUPA


Substantially similar to the procedures specified in


CCR Section 2760.6 <u>Management of Change</u> and
 CCR Section 2760.7 <u>Pre-Startup Safety Review;</u>

























Emergency Response – Accidental Release defined

19 CCR § 2735-3 § 2735-3. Definitions.

CALIFORNIA CUPA FORUM

(a) "Accidental release" means an unanticipated emission of a regulated substance or other extremely hazardous substance into the ambient air from a stationary source.











Accidental Releaseactual incident

A ¾" solenoid valve on one of the compressors liquid injection cooling lines blew the top off of valve (see photo) releasing liquid ammonia in Engine Room.

Operator hit the E-Stop as he was escaping the room.


36th California Unified Program Annual Training Conference February36-29, 3024




Accidental Releaseactual incident

A ¾" solenoid valve on one of the compressors liquid injection cooling lines blew the top off of valve (see photo) releasing liquid ammonia in Engine Room.


Operator hit the E-Stop as he was escaping the room.











Technical Assistance CCR §2785.1

- The owner or operator of astationary source shall closely coordinate with the UPA to ensure that appropriate technical standards are applied to the implementation of this chapter.
- The owner or operator of astationary source shall request assistance from the UPA when necessary to address compliance with this chapter or safety issues regarding unfamiliar processes.

